

# PRE-K/K (ECC) AND ELEMENTARY SCHOOL RENOVATIONS

**Addendum #3  
March 30, 2020**

For

**STAFFORD MUNICIPAL SCHOOL DISTRICT**



MWA Architects, Inc.

**Addendum includes this cover + 1 (one) 8½ x 11 page**

**PRE-K/K (ECC) AND ELEMENTARY SCHOOL RENOVATIONS – ADDENDUM #3**

Proposal Part 1 is due no later than April 2, 2020 by 11:00 am  
Proposal Part 2 is due no later than April 2, 2020 by 4:00 pm  
Proposal bids will be opened and read publicly at 4:30pm.

Proposal packets are to be returned as follows:

Attention: Dedrea Norman, CFO  
Stafford MSD  
1625 Staffordshire Road  
Stafford, TX 77477

To the Plans and Specifications for the Stafford MSD RFP #20 – 002,  
this addendum forms a part of the Contract Documents and modifies  
said documents as follow:



**GENERAL - NONE**

**SPECIFICATIONS - NONE**

**DRAWINGS**

**Item 1.** Sheet E02-01 (ES)

- a. New fan powered terminal box FPT-3 in the library replaces an existing air unit. Disconnect existing unit and reconnect new FPT-3 to existing circuit MA-9, field verify prior to beginning work. Reference mechanical drawings MD01-01 and M01-01 issued in Addendum #2 for location of existing/new unit.

**Item 2.** Sheet E03-00 (ES)

- a. New fan powered terminal box FPT-3 replaces an existing air unit. Per the original drawings this unit is fed from circuit MA-9. Reconnect to existing circuit with 3-12, 3/4"C. Field verify prior to beginning work.

END OF ADDENDUM #3 DESCRIPTION